

**PROCEEDINGS OF THE SECRETARY
TELANGANA STATE BOARD OF INTERMEDIATE EDUCATION
NAMPALLY, HYDERABAD-500001.**

Present : Sri Navin Mittal, I.A.S.,

Rc.No. TSBIE-E/FIRE/MOB/1/2022-E

Date: 23-12-2022.

Sub: TSBIE - Academic - Extension of Provisional Affiliation for the Academic year 2022-23 - Fire Safety Measures to be followed in the Junior Colleges functioning at mixed occupancy buildings - Certain instructions issued - Reg.

- Ref: 1. G.O.Ms. No.72, Home(Serv.IV) Department, dated:23-12-2022
2. G.O.MS.No.95, Home(Serv.IV) Department, dated:05-10-2021.
3. G.O. MS.No .29, Horne (Serv. IV) Department,dated: 24-09-2020.
4. G.O. Ms. No.53, Home (Serv.Iv) Department,d ated: 16-12-2020.
5. From the Secretary, TSBIE, Hyderabad Lr. No. 14/SPL/E2/2021-22, dated:24-06-2021.
6. From the Director TSDR & FS, Hyderabad letter Rc.No. 8109/MSB/2016, dated:12-08-2021.

* * *

The attention of Managements and Principals of all Junior Colleges in the State are invited that the Home (Services-IV) Department has issued orders vide G.O. Ms. No. 72, extending the relaxation to the Junior Colleges running in Mixed Occupancy where the building height is up to 15 metres, for the academic year 2022-23 & 2023-24. During the Academic year 2021-22, G.O. Ms.No.95, Home (Services-IV) Department, dated:05-10-2021 (reference 2nd cited), orders was issued stating that "the instructions in para-4(iii) of G.O.Ms.No.29, Horne (Services-IV) Department, dated: 24-09-2020 are kept in abeyance for one more year i.e., 2021-22 as a special case" and to comply with the same for next year i.e., 2022-23 onwards, relating to the Fire Safety Measures to be followed in Junior Colleges".

Further, it is informed that, as per G.O' Ms. No' 72, "Government after careful examination of the proposal in consultation with the Director General, Telangana State Disaster Response and Fire Services, Hyderabad, hereby order that instructions issued in Para-4(iii) of G.O. Ms. No .29, Home (Services-IV) Department, dated.:24-09-2020 are kept in abeyance for Two(02) Academic years i.e., 2022-23 & 2023-24, as a special case. No further extension will be given.

Further, it is hereby informed that this relaxation is given as a special case and that they are advised to maintain all Fire Safety Systems in good working condition and that they will have to comply with instructions in para-4(iii) of G.O.Ms.No.29, Home (Services-IV) Department, dated: 24-09-2020 relating to the Fire Safety measures from the Academic year 2024-25 onwards.

Signed by Navin Mittal

Date: 26-12-2022 08:33:28

Reason: Approved

SECRETARY

To

All the Managements of Junior Colleges.

Copy to:

All the District Officers of the TSBIE for information.

All the Officers & Staff of the TSBIE for information.

ANNEXURE-II

(Annexure to G.O.Ms.No. 29, Home (Ser.IV) Department, Dated:24.09.2020)

Self Certification report to be submitted by the Junior Colleges

1	Name, Age, Father Name and Address of the Owner(s)/Occupier(s)	
2	Address of the premises	
3	Address for Correspondence (provide phone number, Fax and email id if any)	
4	Height of the Building in Mtrs	
5	Abutting Road Width in Mtrs	
6	Area of the site on sqr metres	_____sq mtrs
7	Total Built-up area of all floors including basements & stilts (in sqm)	_____sq mtrs
8	Whether Type of construction was proposed as per IS 14435:1997 clause 4	YES/NO
9	Whether the Means of Access were proposed as per Clause 4,6 (d) part 3 of NBC, 2016	YES/NO
10	Whether Occupant Load was followed as per Table 4 of NBC 2016 clause 4, 3 and 4.4.2.1	YES/NO
11	MEANS OF ESCAPE	
	Whether the Staircases were proposed as per 4.4.2.4.3.2 e (5) Table 4 of NBC 2016	YES/NO
	Whether the Doors were proposed as per NBC part-4 (4.4.2.4.1)	YES/NO
	Whether the Travel Distance was maintained as per Table 5 part 4 of NBC 2016 clause 4.4.2.1 and 4.4.2.2	YES/NO
	Whether the Corridor Passageways were maintained as per part 4 NBC 2016 clause 4.4.2.4.2	YES/NO

SELF CERTIFICATION REPORT

Self Certification of Fire Safety Measures by Junior College management:

We Junior College Management / Correspondent hereby certify that the information furnished above is correct and if it is noticed at any time that the information provided is false, we understand that our Junior College affiliation may be cancelled by the concerned Authority. We have installed fire safety measures as per the Annexure I and undertake to maintain the same in trim working condition at all times.

Signature:
Designation:

Copy to:
The Divisional Fire Officers of concerned District.